

Certificate of Compliance

Certificate: 1517097

Master Contract: 173350

Project: 2124492

Date Issued: February 13, 2009


Issued to: Kobold Messring GmbH
Nordring 22-24
65719 Hofheim T/s
GERMANY

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: Ghislain Foulem

Authorized by: M.H.J.Hoendervangers
Area Director, Europe



PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT – Miscellaneous Apparatus

CLASS 3211 87 - INDUSTRIAL CONTROL EQUIPMENT – Miscellaneous Apparatus, Certified to US Standards

Flow Control Devices, open type, Types PSR and PSE, resistive ratings, 2 A 20Vac, 0.18 A 230 Vac max 40 W for SPST and 0.13 A 150 Vac, 0.5 A 40Vac 20W for SPDT.

Level Control Devices, open type, Types NV-11 and NV-12, resistive ratings 0.18 A 230 Vac, 2 A 20Vac max 40 W for SPST and 0.13 A 150 Vac, 0.5 A 40Vac 20W for SPDT.

Reed type switch, magnetically operated, open type, spst and spdt contacts Types 41R57, resistive ratings 0.26 A, 230Vdc, 1A 60Vdc, max. 60W, 1A 100 Vac, 0.42 A 240Vac max. 100W.

Flow Control Devices, open type, SPST, Type NKP, rated 0.17A 230Vac/dc, 2A 20Vac/dc, max 40 W

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 14 - 05 - Industrial Control Equipment

US Standard UL508, seventeenth edition

Supplement to Certificate of Compliance

Certificate: 1517097

Master Contract: 173350

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
2124492	February 13, 2009	Update to report to cover new type NKP
2057551	August 07, 200	Update to report to cover Types NV-11, NV-12 and 41R57 Modification of Types PSR and PSE.
1559396	May 26, 2004	Update to report to cover class no. 3211 87
1517097	January 28, 2004	Original Certification of Flow Control Devices, open type. Types PSR and PSE