



Certificate of Compliance

Certificate: 70019793

Master Contract: 167018

Project: 70019793

Date Issued: April 10, 2015

Issued to: Cameron International Corporation

7300 Nix Dr
Duncan, OK 73533
USA
Attention: Thomas Madden

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Jay McVeigh

Issued by: Jay McVeigh

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -
Certified to US Standards

CLASS 2258 03 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non -
Incendive Systems - For Hazardous Locations

CLASS 2258 83 - PROCESS CONTROL EQUIPMENT-Intrinsically Safe and Non-
Incendive - Systems-For Hazardous Locations-Certified to U.S. Standards

Class I Division 1 Groups CD T6

[Exia] Associated Apparatus

Scanner 3100, process I/O module. Rated 9-30 Vdc @ 150 mA. Contains two 7.2 V lithium battery packs. Rated ambient operating temperature: -40°C to +70°C; Encl. Type 4. Multivariable Transducer max working pressure (MWP) 5800 PSI, for ANSI 12.27.01 Single Seal certification MWP up to 3000 PSI. Approved accessories detailed in drawing X-311899. Radio output intrinsically safe when installed per control drawing X-311813.



Certificate: 70019793

Master Contract: 167018

Project: 70019793

Date Issued: April 10, 2015

APPLICABLE REQUIREMENTS

CSA C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

CSA C22.2 No. 94-M1991 - Special Purpose Enclosures

CSA C22.2 No. 142-M1987 - Process Control Equipment

CSA C22.2 No. 157-92 (R2012) - Intrinsically safe and non-incendive equipment for use in hazardous locations

ANSI/ISA 12.27.01-2011 - Requirements for Process Sealing Between Electrical Systems and Flammable or Combustible Process Fluids

UL 50, Eleventh Edition - Enclosures for Electrical Equipment

UL 508, Seventeenth Edition - Industrial Control Equipment

UL 913, Eighth Edition - Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and II, Division 1, Hazardous (Classified) Locations

FM-3600-2011 - Approval Standard for Electrical Equipment for Use in Hazardous (Classified) Locations - General Requirements

FM-3615-2006 - Approval Standard for Explosionproof Electrical Equipment - General Requirements