



Translation

**EC-Type Examination Certificate**

(1)

(2)

**- Directive 94/9/EC -  
Equipment and protective systems intended for use  
in potentially explosive atmospheres**

(3)

**DMT 01 ATEX E 149 X**

(4)

**Equipment: Sensor type TM or TME**

(5)

**Manufacturer: Josef Heinrichs GmbH & Co. Messtechnik KG**

(6)

**Address: D 50739 Köln**

(7)

The design and construction of this equipment and any acceptable variation thereto are specified in the schedule to this type examination certificate.

(8)

The certification body of Deutsche Montan Technologie GmbH, notified body no. 0158 in accordance with Article 9 of the Directive 94/9/EC of the European Parliament and the Council of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive.  
The examination and test results are recorded in the test and assessment report BVS PP 01.2105 EG.

(9)

The Essential Health and Safety Requirements are assured by compliance with:

EN 50014:1997+A1-A2 General requirements  
EN 50020:1994 Intrinsic safety 'i'

(10)

If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

(11)

This EC-Type Examination Certificate relates only to the design, examination and tests of the specified equipment in accordance to Directive 94/9/EC.  
Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate

(12)

The marking of the equipment shall include the following:



**II 2G EEx ia IIC T6 - T2**

**Deutsche Montan Technologie GmbH**

Essen, dated 14. November 2001

Signed: Jockers

Signed: Dill

DMT-Certification body

Head of special services unit



(13) Appendix to

(14) **EC-Type Examination Certificate**

**DMT 01 ATEX E 149 X**

(15) 15.1 Subject and type

Sensor type TM or TME

15.2 Description

The sensor in combination with a transmitter is used for flow measurement in tubes.

The sensor, which consists of magnetically excited oscillating tubes, contains as electrical components coils, resistors, temperature sensors and terminals and connectors.

The sensor can be manufactured with a connection box (mounted separately) or can be mounted close to the transmitter.

15.3 Parameters

15.3.1 Exciter circuit (terminals 9 - 10)

15.3.1.1 for type EC1

voltage	U <sub>i</sub>	30	V
current	I <sub>i</sub>	90	mA
power	P <sub>i</sub>	0,4	W
effective internal capacitance	C <sub>i</sub>	negligible	
effective internal inductance	L <sub>i</sub>	4,5	mH
max. internal inductance/resistance ratio	L <sub>i</sub> /R <sub>i</sub>	0,15	mH/Ω

15.3.1.2 for type EC2 (the transformer is mounted separately)

for the connection of an intrinsically safe circuit type of protection EEx ia IIC with linear output characteristic and the following max. values:

voltage	U <sub>o</sub>	30	V
current	I <sub>o</sub>	90	mA

15.3.2 Sensor circuit (terminals 1 - 2 and 3 - 4)

voltage	U <sub>i</sub>	DC 30	V
current	I <sub>i</sub>	50	mA
power	P <sub>i</sub>	0,375	W
effective internal capacitance	C <sub>i</sub>	negligible	
effective internal inductance	L <sub>i</sub>	14	mH
max. internal inductance/resistance ratio	L <sub>i</sub> /R <sub>i</sub>	0,15	mH/Ω

output voltage	U <sub>o</sub>	AC 0,3	V
----------------	----------------	--------	---

15.3.3 Temperature sensor circuit (terminals 5 - 8)

voltage	U <sub>i</sub>	DC 30	V
current	I <sub>i</sub>	100	mA
power	P <sub>i</sub>	0,333	W
effective internal capacitance	C <sub>i</sub>	negligible	
effective internal inductance	L <sub>i</sub>	negligible	

15.3.4 Ambient temperature range  $T_a$   
depending on type, installation, process temperature and temperature class:

15.3.4.1 separately mounted

type	distance element	process temperature (°C)	ambient temperature range (°C)	temperature class
TM/TME	without	48	-40 up to +48	T6
TM/TME	without	60	-40 up to +60	T5
TM/TME	without	100	-40 up to +60	T4
TM/TME	100 mm	120	-40 up to +60	T4
TM/TME	100 mm	180	-40 up to +60	T3
TM	200 mm	260	-40 up to +60	T2

15.3.4.2 mounted close to the transmitter

Typ	distance element	process temperature (°C)	ambient temperature range (°C)	temperature class
TM/TME	without	48	-40 up to +48	T6
TM/TME	without	60	-40 up to +55	T5
TM/TME	without	100	-40 up to +50	T4
TM/TME	100 mm	120	-40 up to +50	T4
TM/TME	100 mm	150	-40 up to +50	T3

The values for ambient temperature mentioned in the certificate of the transformer have to be regarded.

(16) Test and assessment report  
BVS PP 01.2105 EG as of 14.11.2001

(17) Special conditions for safe use

17.1 If the sensor is mounted separately the equipotential bonding between the transmitter and the sensor has to be made.


17.2 For the application of the sensor in an ambient temperature of less than - 20 °C suitable cables and cable entries suitable for this condition shall be used.

We confirm the correctness of the translation from the German original.  
In the case of arbitration only the German wording shall be valid and binding.

45307 Essen, 14.11.2001  
BVS-Schu/Mi A 20010237

**Deutsche Montan Technologie GmbH**

  
DMT-Certification body

  
Head of special services unit



Translation



## 1st Supplement

(Supplement in accordance with Directive 94/9/EC Annex III number 6)

### to the EC-Type Examination Certificate DMT 01 ATEX E 149 X

**Equipment:** Mass flow sensor type TM or TME  
**Manufacturer:** Heinrichs Messtechnik GmbH  
former Josef Heinrichs GmbH & Co. Messtechnik KG  
**Address:** D - 50739 Köln

#### Description

The flow sensor may be used in such a way that in the measuring tubes explosive atmosphere may be present often or for a long time, marking

II 1/2 G EEx ia IIC T6 – T2

The Essential Health and Safety Requirements of the modified equipment are assured by compliance with:

EN 50014:1997+A1-A2 General requirements  
EN 50020:2002 Intrinsic safety 'i'  
EN 50284:1999 Equipment Group II Category 1G

#### Test and assessment report

BVS PP 01.2105 EG as of 26.08.2003

#### Special conditions for safe use

- 1 If the sensor is mounted separately; the equipotential bonding between the transmitter and the sensor has to be done.
- 2 For the application of the sensor in an ambient temperature of less than - 20 °C suitable cables and cable entries suitable for this condition shall be used.
- 3 The measuring tubes built of corrosion-resistant steel have a thickness of < 1 mm: For the use it must be sure that risks e.g. by the medium or mechanical damages are excluded.



## Deutsche Montan Technologie GmbH

Bochum, dated 26. August 2003

signed: Migenda

EXAM Certification body

signed: Leiendecker


Special services unit

---

We confirm the correctness of the translation from the German original.  
In the case of arbitration only the German wording shall be valid and binding.

44809 Bochum, 26.08.2003  
BVS-Schu/Ar A 20030614

**Deutsche Montan Technologie GmbH**

  
EXAM Certification body

  
Special services unit



**Translation**

**2<sup>nd</sup> Supplement**

(Supplement in accordance with Directive 94/9/EC Annex III number 6)

**to the EC-Type Examination Certificate  
DMT 01 ATEX E 149 X**

**Equipment:** Mass flow sensor type TM or TME

**Manufacturer:** Heinrichs Messtechnik GmbH

**Address:** D - 50739 Köln

Description

The sensor can be modified according to the descriptive documents as mentioned in the pertinent test and assessment report and gets the denomination

type TMU

The Essential Health and Safety Requirements of the modified equipment are assured by compliance with:

EN 50014:1997+A1-A2 General requirements  
EN 50020:2002 Intrinsic safety 'i'  
EN 50284:1999 Equipment Group II Category 1G

Test and assessment report

BVS PP 01.2105 EG as of 05.11.2004

**EXAM BBG Prüf- und Zertifizier GmbH**

Bochum, dated 05. November 2004

Signed: Dr. Jockers

\_\_\_\_\_  
Certification body

Signed: Dr. Eickhoff

\_\_\_\_\_  
Special services unit



**Translation**

**3rd Supplement**

(Supplement in accordance with Directive 94/9/EC Annex III number 6)

**to the EC-Type Examination Certificate  
DMT 01 ATEX E 149 X**

**Equipment:** Mass flow sensor type TM, TME, TMU or TMR  
**Manufacturer:** Heinrichs Messtechnik GmbH  
**Address:** 50739 Cologne, Germany

Description

The sensor can be modified according to the descriptive documents as mentioned in the pertinent test and assessment report.

The types TM, TME and TMU can be used in an ambient temperature range up to +100 °C in temperature classes T2, T3 and T4.

A new sensor is also available:

**Type TMR**

The Essential Health and Safety Requirements of the modified equipment are assured by compliance with:

EN 50014:1997+A1-A2    General requirements  
EN 50020:2002        Intrinsic safety 'i'  
EN 50284:1999        Equipment Group II Category 1G

The marking of the equipment shall include the following:

 **II 1/2G EEx ia IIC T6 – T2**

Parameters

1	Type TMR			
1.1	Exciter circuit (terminals/connector pin 9 - 10)			
1.1.1	for type EC1			
	voltage	U <sub>i</sub>	30	V
	current	I <sub>i</sub>	90	mA
	power	P <sub>i</sub>	0,4	W
	effective internal capacitance	C <sub>i</sub>	negligible	
	effective internal inductance	L <sub>i</sub>	4,5	mH
	max. internal inductance/resistance ratio	L <sub>i</sub> /R <sub>i</sub>	0,1	mH/Ω

- 1.1.2 for type EC2 (the transformer is mounted separately)  
for the connection of an intrinsically safe circuit type of protection EEx ia IIC with linear output characteristic and the following max. values:

voltage	U <sub>o</sub>	30	V
current	I <sub>o</sub>	90	mA
power	P <sub>o</sub>	1	W

- 1.2 Sensor circuit (terminals/connector pin 1 - 2 and 3 - 4)

voltage	U <sub>i</sub>	DC	30	V
current	I <sub>i</sub>		50	mA
power	P <sub>i</sub>		0,4	W
effective internal capacitance	C <sub>i</sub>	negligible		
effective internal inductance	L <sub>i</sub>		14	mH
max. internal inductance/resistance ratio	L <sub>i</sub> /R <sub>i</sub>		0,17	mH/Ω
output voltage	U <sub>o</sub>	AC	0,3	V

- 1.3 Temperature sensor circuit (terminals/connector pin 5 - 8)

voltage	U <sub>i</sub>	DC	30	V
current	I <sub>i</sub>		100	mA
power	P <sub>i</sub>		0,333	W
effective internal capacitance	C <sub>i</sub>	negligible		
effective internal inductance	L <sub>i</sub>	negligible		

- 4.2 For types TM, TME, TMU and TMR

Ambient temperature range  $T_a$   
depending on the type, the installation, the process temperature and the temperature class:

- 4.2.1 with connector

distance element	process temperature (°C)	ambient temperature range (°C)	temperature class
without	+45	-40 bis +45	T6
without	+60	-40 bis +60	T5
60 mm	+100	-40 bis +100	T4
160 mm	+120	-40 bis +100	T4
160 mm	+180	-40 bis +100	T3
260 mm	+260	-40 bis +100	T2

- 4.2.2 removed mounted

distance element	process temperature (°C)	ambient temperature range (°C)	temperature class
without	+45	-40 bis +45	T6
without	+60	-40 bis +60	T5
without	+100	-40 bis +100	T4
100 mm	+120	-40 bis +100	T4
100 mm	+180	-40 bis +100	T3
200 mm	+260	-40 bis +100	T2



4.2.3 mounted close to the transmitter

distance element	process temperature (°C)	ambient temperature range (°C)	temperature class
without	+45	+45	T6
without	+60	+55	T5
without	+100	+50	T4
100 mm	+120	+50	T4
100 mm	+150	+50	T3

The values for ambient temperature mentioned in the certificate of the transformer have to be regarded.

Special conditions for safe use

- 1 If the sensor is mounted separately; the equipotential bonding between the transmitter and the sensor has to be done.
- 2 For the application of the sensor in an ambient temperature of less than -20 °C and higher than +60 °C suitable cables and cable entries suitable for this condition shall be used.
- 3 The measuring tubes built of corrosion-resistant steel have a thickness of < 1 mm: For the use it must be sure that risks e.g. by the medium or mechanical damages are excluded.

Test and assessment report

BVS PP 01.2105 EG as of 30.11.2006

**EXAM BBG Prüf- und Zertifizier GmbH**

Bochum, dated 30. November 2006

Signed: Dr. Jockers

\_\_\_\_\_  
Certification body

Signed: Dr. Eickhoff

\_\_\_\_\_  
Special services unit

We confirm the correctness of the translation from the German original.  
In the case of arbitration only the German wording shall be valid and binding.

44809 Bochum, 30. November 2006  
BVS-Schu/Kw A 20060792

**EXAM BBG Prüf- und Zertifizier GmbH**

  
\_\_\_\_\_  
Certification body

  
\_\_\_\_\_  
Special services unit



Translation

## 4<sup>th</sup> Supplement

(Supplement in accordance with Directive 94/9/EC Annex III number 6)

### to the EC-Type Examination Certificate DMT 01 ATEX E 149 X

**Equipment:** Mass flow sensor type TM, TME, TMU, TMR resp. TMS  
**Manufacturer:** Heinrichs Messtechnik GmbH  
**Address:** 50739 Cologne, Germany

#### Description

The types TM, TME, TMU and TMR have been evaluated in accordance with the standards EN 60079-\* and a new variation is available:

**Type TMS**

The Essential Health and Safety Requirements of the modified equipment are assured by compliance with:

EN 60079-0:2006 General requirements  
EN 60079-11:2007 Intrinsic safety 'i'  
EN 60079-26:2004 Equipment Group II Category 1G

The marking of the equipment shall include the following:

II 1/2G Ex ia IIC T6-T2

#### Parameters

1 Types TM, TME, TMU and TMR  
not changed

2 Type TMS

2.1 Exciter circuit (contacts 1 - 2)

Voltage	Ui	30	V
Current for Group IIC Classification	Ii	130	mA
Current for Group IIB Classification	Ii	280	mA
Power	Pi	0.5	W
Internal capacitance	Ci	negligible	
Internal inductance	Li	2	mH

**2.2 Sensor circuit (contacts 5 - 6 and 7 - 8)**

Voltage	U <sub>i</sub>	DC	30	V
Current for Group IIC Classification	I <sub>i</sub>		50	mA
Current for Group IIB Classification	I <sub>i</sub>		100	mA
Power	P <sub>i</sub>		0.4	W
Internal capacitance	C <sub>i</sub>		negligible	
Internal inductance	L <sub>i</sub>		14	mH
Output voltage	U <sub>o</sub>	AC	0.3	V

**2.3 Temperature sensor circuit (contacts 3 - 4)**

Voltage	U <sub>i</sub>	DC	30	V
Current	I <sub>i</sub>		100	mA
Power	P <sub>i</sub>		0.1	W
Internal capacitance	C <sub>i</sub>		negligible	
Internal inductance	L <sub>i</sub>		negligible	

**2.4 Ambient temperature range** Ta  
 Depending on the process temperature and the temperature class:

Process temperature -50 °C up to (°C)	Ambient temperature range (°C)	Temperature class
125	-40 up to +60	T4
70	-40 up to +60	T5

Special conditions for safe use

- 1 If the sensor is mounted separately; the equipotential bonding between the transmitter and the sensor has to be done.
- 2 For the application of the sensor in an ambient temperature of less than - 20 °C and higher than +60 °C suitable cables and cable entries suitable for this condition shall be used.
- 3 The measuring tubes built of corrosion-resistant steel have a thickness of < 1 mm. For the use it must be sure that risks e.g. by the medium or mechanical damages are excluded.

Test and assessment report

BVS PP 01.2105 EG as of 14.02.2008

**DEKRA EXAM GmbH**

Bochum, dated 14. February 2008

Signed: Dr. Jockers

Certification body

Signed: Dr. Eickhoff

Special services unit

---

We confirm the correctness of the translation from the German original.  
In the case of arbitration only the German wording shall be valid and binding.

44809 Bochum, 14.02.2008  
BVS-Schu/Wa A 20080042

**DEKRA EXAM GmbH**

  
\_\_\_\_\_  
Certification body  
\_\_\_\_\_  
Special services unit



Translation

## 5<sup>th</sup> Supplement

(Supplement in accordance with Directive 94/9/EC Annex III number 6)

### to the EC-Type Examination Certificate DMT 01 ATEX E 149 X

**Equipment:** Mass flow sensor type TM, TME, TMU, TMR resp. TMS  
**Manufacturer:** Heinrichs Messtechnik GmbH  
**Address:** 50739 Köln, Germany

#### Description

The flow sensors can be modified according to the descriptive documents as mentioned in the pertinent test and assessment report; the type TMS will be modified and the following variations are possible:

Type TMS with Exciter circuit EC1 resp.  
Type TMS with Exciter circuit EC2

The Essential Health and Safety Requirements of the modified equipment are assured by compliance with:

EN 60079-0:2006 General requirements  
EN 60079-11:2007 Intrinsic safety 'i'  
EN 60079-26:2004 Equipment Group II Category IG

The marking of the equipment shall include the following:

 II 1/2G Ex ia IIC T6-T2

#### Parameters

1	Types TM, TME, TMU and TMR not changed		
2	Type TMS		
2.1	Exciter circuit (contacts 1 - 2)		
2.1.1	Circuit EC1		
	Voltage	Ui	30 V
	Current for Group IIC Classification	Ii	130 mA
	Current for Group IIB Classification	Ii	280 mA
	Power	Pi	0.5 W
	Internal capacitance	Ci	negligible
	Internal inductance	Li	2 mH

2.1.2 Circuit EC2 (the transmitter is mounted separately)

For the connection of an intrinsically safe circuit level of protection Ex ia and the following maximum values:

Voltage	U <sub>o</sub>	30	V
Current for Group IIC Classification	I <sub>o</sub>	130	mA
Current for Group IIB Classification	I <sub>o</sub>	280	mA
Power	P <sub>o</sub>	0.5	W

2.2 Sensor circuit (contacts 5 - 6 and 7 - 8)

Voltage	U <sub>i</sub>	DC	30	V
Current for Group IIC Classification	I <sub>i</sub>		50	mA
Current for Group IIB Classification	I <sub>i</sub>		100	mA
Power	P <sub>i</sub>		0.4	W
Internal capacitance	C <sub>i</sub>		negligible	
Internal inductance	L <sub>i</sub>		14	mH
Output voltage	U <sub>o</sub>	AC	0.3	V

2.3 Temperature sensor circuit (contacts 3 - 4)

Voltage	U <sub>i</sub>	DC	30	V
Current	I <sub>i</sub>		100	mA
Power	P <sub>i</sub>		0.1	W
Internal capacitance	C <sub>i</sub>		negligible	
Internal inductance	L <sub>i</sub>		negligible	

2.4 Ambient temperature range T<sub>a</sub>

depending on the process temperature and the temperature class:

Process temperature -50 °C up to (°C)	Ambient temperature range (°C)	Temperature class
125	-40 up to +60	T4
70	-40 up to +60	T5

Special conditions for safe use

- 1 If the sensor is mounted separately; the equipotential bonding between the transmitter and the sensor has to be done.
- 2 For the application of the sensor in an ambient temperature of less than - 20 °C and higher than +60 °C suitable cables and cable entries suitable for this condition shall be used.
- 3 The measuring tubes built of corrosion-resistant steel have a thickness of < 1 mm: For the use it must be sure that risks e.g. by the medium or mechanical damages are excluded.

Test and assessment report

BVS PP 01.2105 EG as of 09.09.2010

**DEKRA EXAM GmbH**  
Bochum, dated 09<sup>th</sup> September 2010

Signed: Hans Christian Simanski

Signed: Dr. Franz Eickhoff

---

Certification body

---

Special services unit

---

We confirm the correctness of the translation from the German original.  
In the case of arbitration only the German wording shall be valid and binding.

44809 Bochum, 09.09.2010  
BVS-Schu/Ar A 20100643

**DEKRA EXAM GmbH**



---

Certification body



---

Special services unit

## Translation

# (1) 6. Supplement to the EC-Type Examination Certificate

(2) Equipment and protective systems intended for use in potentially explosive atmospheres - Directive 94/9/EC Supplement accordant with Annex III number 6

(3) No. of EC-Type Examination Certificate: **DMT 01 ATEX E 149 X**

(4) Equipment: **Mass flow sensor type TM, TME, TMU, TMR resp. TMS**

(5) Manufacturer: **Heinrichs Messtechnik GmbH**

(6) Address: **Robert-Perthel-Straße 9, 50739 Köln, Germany**

(7) The design and construction of this equipment and any acceptable variation thereto are specified in the appendix to this supplement.

(8) The certification body of DEKRA EXAM GmbH, notified body no. 0158 in accordance with Article 9 of the Directive 94/9/EC of the European Parliament and the Council of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive. The examination and test results are recorded in the Test and Assessment Report BVS PP 01.2105 EG.

(9) The Essential Health and Safety Requirements are assured by compliance with:

**EN 60079-0:2012**

**General requirements**

**EN 60079-11:2012**

**Intrinsic safety 'i'**

**EN 60079-26:2007 + Corr. 2009**

**Equipment with equipment protection level (EPL) Ga**

(10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the appendix to this certificate.

(11) This supplement to the EC-Type Examination Certificate relates only to the design, examination and tests of the specified equipment in accordance to Directive 94/9/EC. Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.

(12) The marking of the equipment shall include the following:



**II 1/2G Ex ia IIC T6 – T2 Ga/Gb resp.  
II 1/2G Ex ia IIC T5 / T4 Ga/Gb (type TMS)**

DEKRA EXAM GmbH  
Bochum, dated 22<sup>nd</sup> May 2013

Signed: Hans-Christian Simanski

Signed: Franz Eickhoff

Certification body

Special services unit



- (13) Appendix to
- (14) **6. Supplement to the EC-Type Examination Certificate  
DMT 01 ATEX E 149 X**
- (15) 15.1 Subject and type

Mass flow sensor type TM, TME, TMU, TMR resp. TMS

15.2 Description

The mass flow sensors can be modified according to the descriptive documents as mentioned in the pertinent Test and Assessment Report. The sensors have been evaluated in acc. with the current standard versions, a modified marking is the result.

15.3 Parameters

15.3.1 Type TM resp. TME resp. TMU resp. TMR

15.3.1.1 Exciter circuit (terminals 9 - 10)

15.3.1.1.1 For type EC1

Voltage	$U_i$	30	V
Current	$I_i$	90	mA
Power	$P_i$	0,4	W
Effective internal capacitance	$C_i$	negligible	
Effective internal inductance	$L_i$	4,5	mH

15.3.1.1.2 For type EC2 (the transformer is mounted separately)

For the connection of an intrinsically safe circuit type of protection Ex ia IIC with linear output characteristic and the following max. values:

Voltage	$U_o$	30	V
Current	$I_o$	90	mA
Power	$P_o$	1	W

15.3.1.2 Sensor circuit (terminals 1 - 2 and 3 - 4)

Voltage	$U_i$	DC 30	V
Current	$I_i$	50	mA
Power	$P_i$	0.375	W
Effective internal capacitance	$C_i$	negligible	
Effective internal inductance	$L_i$	14	mH
Output voltage	$U_o$	AC 0.3	V

15.3.1.3 Temperature sensor circuit (terminals 5 - 8)

Voltage	$U_i$	DC 30	V
Current	$I_i$	100	mA
Power	$P_i$	0.333	W
Effective internal capacitance	$C_i$	negligible	
Effective internal inductance	$L_i$	negligible	

15.3.2 Type TMS

15.3.2.1 Exciter circuit (contacts 1 - 2)

Circuit EC1

Voltage	$U_i$	30	V
Current for Group IIC Classification	$I_i$	130	mA
Current for Group IIB Classification	$I_i$	280	mA
Power	$P_i$	0.5	W
Effective internal capacitance	$C_i$	negligible	
Effective internal inductance	$L_i$	2	mH



15.3.2.1.2 Circuit EC2 (the transmitter is mounted separately)

For the connection of an intrinsically safe circuit level of protection Ex ia with the following maximum values:

Voltage	$U_o$	30	V
Current for Group IIC Classification	$I_o$	130	mA
Current for Group IIB Classification	$I_o$	280	mA
Power	$P_o$	0.5	W

15.3.2.2 Sensor circuit (contacts 5 - 6 and 7 - 8)

Voltage	$U_i$	DC 30	V
Current for Group IIC Classification	$I_i$	50	mA
Current for Group IIB Classification	$I_i$	100	mA
Power	$P_i$	0.4	W
Effective internal capacitance	$C_i$	negligible	
Effective internal inductance	$L_i$	14	mH
Output voltage	$U_o$	AC 0.3	V

15.3.2.3 Temperature sensor circuit (contacts 3 - 4)

Voltage	$U_i$	DC 30	V
Current	$I_i$	100	mA
Power	$P_i$	0.1	W
Effective internal capacitance	$C_i$	negligible	
Effective internal inductance	$L_i$	negligible	

15.3.3 Ambient temperature range

depending on the type, the installation, the process temperature and the temperature class:

15.3.3.1 for types TM, TME, TMU and TMR

15.3.3.1.1 with connector

distance element	process temperature (°C)	ambient temperature range (°C)	temperature class
without	45	-40 up to +45	T6
without	60	-40 up to +60	T5
60 mm	100	-40 up to +100	T4
160 mm	120	-40 up to +100	T4
160 mm	180	-40 up to +100	T3
260 mm	260	-40 up to +100	T2

15.3.3.1.2 removed mounted

distance element	process temperature (°C)	ambient temperature range (°C)	temperature class
without	45	-40 up to +45	T6
without	60	-40 up to +60	T5
without	100	-40 up to +100	T4
100 mm	120	-40 up to +100	T4
100 mm	180	-40 up to +100	T3
200 mm	260	-40 up to +100	T2

15.3.3.1.3 mounted close to the transmitter

distance element	process temperature (°C)	Max. ambient temperature (°C)	temperature class
without	45	+45	T6
without	60	+55	T5
without	100	+50	T4
100 mm	120	+50	T4
100 mm	150	+50	T3



The values for ambient temperature mentioned in the certificate of the transformer have to be regarded.

15.3.3.2 for type TMS

$T_a$

Process temperature -50 °C up to (°C)	Ambient temperature range (°C)	Temperature class
125	-40 up to +60	T4
70	-40 up to +60	T5

(16) Test and Assessment Report

BVS PP 01.2105 EG as of 22.05.2013

(17) Special conditions for safe use

- 17.1 If the sensor is mounted separately; the equipotential bonding between the transmitter and the sensor has to be done.
- 17.2 For the application of the sensor in an ambient temperature of less than -20 °C and higher than +60 °C suitable cables and cable entries suitable for this condition shall be used.
- 17.3 The measuring tubes built of corrosion-resistant steel have a thickness of < 1 mm: For the use it must be sure that risks e.g. by the medium or mechanical damages are excluded.

---

We confirm the correctness of the translation from the German original.  
In the case of arbitration only the German wording shall be valid and binding.

DEKRA EXAM GmbH  
44809 Bochum, 22<sup>nd</sup> May 2013  
BVS-Schu/Mu A 20130268



Certification body



Special services unit



Translation

# EU-Type Examination Certificate Supplement 7

Change to Directive 2014/34/EU

Equipment intended for use in potentially explosive atmospheres  
Directive 2014/34/EU

EU-Type Examination Certificate Number: **DMT 01 ATEX E 149 X**

Product: **Mass flow sensor TM families**

Manufacturer: **Heinrichs Messtechnik GmbH**

Address: **Robert-Perthel-Straße 9, 50739 Köln, Germany**

This supplementary certificate extends EC-Type Examination Certificate No. DMT 01 ATEX E 149 X to apply to products designed and constructed in accordance with the specification set out in the appendix of the said certificate but having any acceptable variations specified in the appendix to this certificate and the documents referred to therein.

DEKRA EXAM GmbH, Notified Body number 0158, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.  
The examination and test results are recorded in the confidential Report No. BVS PP 01.2105 EU.


The Essential Health and Safety Requirements are assured in consideration of:

**EN 60079-0:2012 + A11:2013**    **General requirements**  
**EN 60079-11:2012**            **Intrinsic Safety "i"**  
**EN 60079-26:2015**            **Equipment with equipment protection level (EPL) Ga**

If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Special Conditions for Use specified in the appendix to this certificate.

This EU-Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

The marking of the product shall include the following:

 **II 1/2G Ex ia IIC T2...T6 Ga/Gb**

See tables section 15 for details

DEKRA EXAM GmbH  
Bochum, 2018-11-07

Signed: Jörg Koch

Certifier

Signed: Deniz Pezzutto

Approver



13 **Appendix**  
 14 **EU-Type Examination Certificate**

**DMT 01 ATEX E 149 X**  
**Supplement 7**

15 **Product description**

15.1 **Subject and type**

Mass flow sensor TM families

Type TM-ABC-DEFGHIJK-LMNO-P-Q-R-S

A B C D E F G H I J K L M N O P Q R S T U V

- A Wetted Material**
  - Not relevant
- B C Flow-rate Range**
  - - Not relevant
- D E F G Process connection**
  - - - - Not relevant
- H I J K Installation length**
  - - - - Not relevant
- L Enclosure options**
  - Not relevant
- M Heating / Cooling**
  - Not relevant
- N Flow direction**
  - Not relevant
- O Sensor Configurations**
  - 1 Mounted transmitter -20 °C to 100 °C
  - 2 Mounted transmitter -20 °C to 150 °C
  - 3 Remote transmitter (M20x1.5) -40 °C to 100 °C
  - 4 Remote transmitter (M20x1.5) -40 °C to 180 °C
  - 5 Remote transmitter (M20x1.5) -40 °C to 260 °C
  - 6 Remote transmitter (1/2" NPT) -40 °C to 100 °C
  - 7 Remote transmitter (1/2" NPT) -40 °C to 180 °C
  - 8 Remote transmitter (1/2" NPT) -40 °C to 260 °C
- P Approvals**
  - L ATEX / IECEx – Supplement 7 onwards
- Q Certificates**
  - Not relevant
- R Supplementary equipment**
  - Not relevant
- S T U V Additional options**
  - - - - Not relevant

Type TME-ABC-DEFGHIJ-K-L-M-N

A B C D E F G H I J K L M N

- A Wetted Material**
  - Not relevant
- B C Flow-rate Range**
  - - Not relevant
- D E F G Process connection**
  - - - - Not relevant
- H Heating / Cooling**
  - Not relevant
- I Flow direction**
  - Not relevant
- J Sensor Configurations**
  - 1 Mounted transmitter -20 °C to 100 °C
  - 2 Mounted transmitter -20 °C to 150 °C
  - 3 Remote transmitter (M20x1.5) -40 °C to 100 °C
  - 4 Remote transmitter (M20x1.5) -40 °C to 180 °C
  - 6 Remote transmitter (1/2" NPT) -40 °C to 100 °C
  - 7 Remote transmitter (1/2" NPT) -40 °C to 180 °C
- K Approvals**
  - L ATEX / IECEx – Supplement 7 onwards
- L Certificates**
  - Not relevant
- M Supplementary equipment**
  - Not relevant
- N Design**
  - Not relevant





Type TMR-ABC-DEFGHIJK-LMNO-P-Q-R

A B C D E F G H I J K L M N O P Q R

**A Wetted Material**

- Not relevant

**B C Flow-rate Range**

- - Not relevant

**D E F G Process connection**

- - - - Not relevant

**H I J K Installation length**

- - - - Not relevant

**L Enclosure options**

- Not relevant

**M Heating / Cooling**

- Not relevant

**N Flow direction**

- Not relevant

**O Sensor Configurations**

- 1 Mounted transmitter -20 °C to 100 °C
- 2 Mounted transmitter -20 °C to 150 °C
- 3 Remote transmitter (M20x1.5) -40 °C to 100 °C
- 4 Remote transmitter (M20x1.5) -40 °C to 180 °C
- 5 Remote transmitter (M20x1.5) -40 °C to 260 °C
- 6 Remote transmitter (1/2" NPT) -40 °C to 100 °C
- 7 Remote transmitter (1/2" NPT) -40 °C to 180 °C
- 8 Remote transmitter (1/2" NPT) -40 °C to 260 °C

**P Approvals**

L ATEX / IECEx – Supplement 7 onwards

**Q Certificates**

- Not relevant

**R Supplementary equipment**

- Not relevant

Type TM-SH-ABCD-EFGH-IJK-LM-NO-P-Q

A B C D E F G H I J K L M N O P Q

**A B Model / Range**

- - Not relevant

**C D Wetted Material**

- - Not relevant

**E F G H Process connection**

- - - - Not relevant

**I Enclosure options**

- Not relevant

**J Enclosure Filling**

- Not relevant

**K Heating / Cooling**

- Not relevant

**L Sensor Configurations**

K Remote transmitter -40 °C to 60 °C - connection via HAN R23 connector

L Remote transmitter -40 °C to 100 °C - connection via HAN R23 connector

X Customer specified - connection via HAN R23 connector

**M Approvals**

L ATEX / IECEx – Supplement 7 onwards

**N Calibration Flow**

- Not relevant

**O Calibration Density**

- Not relevant

**P Supplementary equipment**

- Not relevant

**Q Design**

- Not relevant



Type TMU-ABCD-EFGH-IJK-LM-NO-P-Q

A B C D E F G H I J K L M N O P Q

- A Wetted Material
  - Not relevant
- B C D Model size
  - - - Not relevant
- E F G H Process connection
  - - - - Not relevant
- I Enclosure options
  - Not relevant
- J Heating / Cooling
  - Not relevant
- K Heating / Cooling connections
  - Not relevant
- L Sensor Configurations
  - A Mounted transmitter -20 °C to 100 °C
  - B Mounted transmitter -20 °C to 150 °C
  - C Remote transmitter (1/2" NPT) -40 °C to 100 °C
  - D Remote transmitter (1/2" NPT) -40 °C to 180 °C
  - E Remote transmitter (1/2" NPT) -40 °C to 260 °C
  - F Remote transmitter (M20x1.5) -40 °C to 100 °C
  - G Remote transmitter (M20x1.5) -40 °C to 180 °C
  - H Remote transmitter (M20x1.5) -40 °C to 260 °C
  - K Remote transmitter -40 °C to 100 °C - connection via HAN R23 connector
  - L Remote transmitter -40 °C to 180 °C - connection via HAN R23 connector
  - M Remote transmitter -40 °C to 260 °C - connection via HAN R23 connector
  - X Customer specified
- M Approvals
  - L ATEX / IECEx – Supplement 7 onwards
- N Calibration Flow
  - Not relevant
- O Calibration Density
  - Not relevant
- P Supplementary equipment
  - Not relevant
- Q Design
  - Not relevant

Type TMS-ABCD-EFGH-IJK-LM-NO-P

A B C D E F G H I J K L M N O P

- A Wetted Material
  - Not relevant
- B C D Model size
  - - - Not relevant
- E F G H Process connection
  - - - - Not relevant
- I Enclosure options
  - Not relevant
- J Heating / Cooling
  - Not relevant
- K Heating / Cooling connections
  - Not relevant
- L Sensor Configurations
  - J Remote transmitter (M20x1.5) -50 °C to 125 °C
- M Approvals
  - A ATEX / IECEx
- N Calibration Flow
  - Not relevant
- O Calibration Density
  - Not relevant
- P Supplementary equipment
  - Not relevant



With this supplement the certificate is changed to Directive 2014/34/EU.  
(Annotation: In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20 April 2016.)

#### Subject of the supplement

- Change to Directive 2014/34/EU
- Introduction of new type sensors: TM-\*\*\*-\*\*\*\*\*-\*\*\*\*-L-\*\*-\*\* resp. TME-\*\*\*-\*\*\*\*\*-L-\*\*-\*\* resp. TMU-\*\*\*\*-\*\*\*\*\*-\*\*L-\*\*-\*\* resp. TMR-\*\*\*-\*\*\*\*\*-\*\*\*\*-L-\*\*-\*\* resp. TM-SH-\*\*\*\*-\*\*\*\*\*-\*\*L-\*\*-\*\*
- Adjustment of the electrical parameters for the new sensors
- Modifications of the junction box, the connection board and the limiter circuitry
- Introduction of a new set of printed circuit boards for coil mounting in the type TM-SH-\*\*\*\*-\*\*\*\*\*-\*\*L-\*\*-\*\*.
- Extension by alternative designs with amendments to the excitation circuit and temperature sensor.
- The sensor types TM, TME, TMU and TMR approved with the EC-Type Examination Certificate DMT 01 ATEX E 149 X Supplement 6, shall no longer be produced, and are therefore no longer available for delivery.
- The type TMS-\*\*\*\*-\*\*\*\*\*-\*\*A-\*\*-\*\* remains unchanged.

#### Description of Product:

The Coriolis sensors are used in combination with a transmitter for mass-flow measurement in pipes. The mass flow sensors consisting of magnetically excited vibrating tubes, contains the electrical components, coils, resistors, temperature sensors as well as terminals and connectors for connection to the associated transmitter. The transmitter can be mounted directly on the sensor or separately connected by a cable.

The design of the sensor system is variable. The sensors can be adapted to different plant and process conditions by using a variety of materials and process connections. The Coriolis sensor can be used in applications where an explosive atmosphere can be present in the measuring tubes frequently or over a longer period of time.

The following variations of the sensor are possible:

Type TM-\*\*\*-\*\*\*\*\*-\*\*\*\*-L-\*\*-\*\*  
 Type TME-\*\*\*-\*\*\*\*\*-L-\*\*-\*\*  
 Type TMU-\*\*\*\*-\*\*\*\*\*-\*\*L-\*\*-\*\*  
 Type TMR-\*\*\*-\*\*\*\*\*-\*\*\*\*-L-\*\*-\*\*  
 Type TM-SH-\*\*\*\*-\*\*\*\*\*-\*\*L-\*\*-\*\*  
 Type TMS-\*\*\*\*-\*\*\*\*\*-\*\*A-\*\*-\*\*



## 15.3 Parameters

15.3.1 Type TM-\*\*\*-\*\*\*\*\*-\*\*\*\*-L-\*\*\* resp. type TME-\*\*\*-\*\*\*\*\*-L-\*\*\* resp.  
type TMU-\*\*\*-\*\*\*\*\*-\*\*\*-L-\*\*\* resp. type TMR-\*\*\*-\*\*\*\*\*-\*\*\*\*-L-\*\*\* resp.  
type TM-SH-\*\*\*-\*\*\*\*\*-\*\*\*-L-\*\*\*

### 15.3.1.1 Exciter circuit

For exciter circuit type EC1 (terminals 9 - 10) or exciter circuit type EC1R (terminals 8 - 9)

Voltage	$U_i$	30 V
Current	$I_i$	90 mA
Power	$P_i$	0.4 W
Effective internal capacitance	$C_i$	negligible
Effective internal inductance	$L_i$	4.38 mH

For exciter circuit type EC2 (terminals 9 - 10) or exciter circuit type EC2R (terminals 8 - 9)

For the connection of an intrinsically safe circuit type of protection Ex ia IIC with linear output characteristic and the following max. values:

Voltage	$U_o$	30 V
Current	$I_o$	90 mA
Power	$P_o$	0.8 W

### 15.3.1.2 Sensor circuit (terminals 1 - 2 and 3 - 4)

Voltage	$U_i$	DC	30 V
Current	$I_i$		50 mA
Power	$P_i$		0.3 W
Effective internal capacitance	$C_i$		negligible
Effective internal inductance	$L_i$		14 mH

Output voltage	$U_o$	AC	0.3V
----------------	-------	----	------

### 15.3.1.3 Temperature sensor circuit (terminals 5 - 8 for type EC1 or type EC2; terminals 5 - 7 for type EC1R or type EC2R)

Voltage	$U_i$	DC	30 V
Current	$I_i$		100 mA
Power	$P_i$		0.1 W

15.3.2 Type TMS-\*\*\*-\*\*\*\*\*-\*\*\*-A-\*\*\*

### 15.3.2.1 Exciter circuit (contacts 1 - 2)

Exciter circuit EC1

Voltage	$U_i$	30 V
Current for Group IIC Classification	$I_i$	130 mA
Current for Group IIB Classification	$I_i$	280 mA
Power	$P_i$	0.5 W
Effective internal capacitance	$C_i$	negligible
Effective internal inductance	$L_i$	2 mH

Exciter circuit EC2 (the transmitter is mounted separately)

For the connection of an intrinsically safe circuit level of protection Ex ia with the following maximum values:

Voltage	$U_o$	30 V
Current for Group IIC Classification	$I_o$	130 mA
Current for Group IIB Classification	$I_o$	280 mA
Power	$P_o$	0.5 W

### 15.3.2.2 Sensor circuit (contacts 5 - 6 and 7 - 8)

Voltage	$U_i$	DC	30 V
Current for Group IIC Classification	$I_i$		50 mA
Current for Group IIB Classification	$I_i$		100 mA
Power	$P_i$		0.4 W
Effective internal capacitance	$C_i$		negligible
Effective internal inductance	$L_i$		14 mH
Output voltage	$U_o$	AC	0.3V



15.3.2.3 Temperature sensor circuit (contacts 3 - 4)

Voltage	$U_i$	DC	30	V
Current	$I_i$		100	mA
Power	$P_i$		0.1	W

15.3.3 Ambient temperature range

$T_a$

depending on the type of electrical connection, the installation, the process temperature and the temperature class:

15.3.3.1 For type TM-\*\*\*-\*\*\*\*\*-\*\*\*-L-\*\*-\*\* resp. type TME-\*\*\*-\*\*\*\*\*-L-\*\*-\*\* resp. type TMU-\*\*\*-\*\*\*\*\*-\*\*\*-L-\*\*-\*\* resp. type TMR-\*\*\*-\*\*\*\*\*-\*\*\*-L-\*\*-\*\* resp. type TM-SH-\*\*\*-\*\*\*\*\*-\*\*\*-L-\*\*-\*\*

15.3.3.1.1 Mounted separately with a HAN R23 connector

Neck extension element	Process temperature (°C)	Ambient temperature range (°C)	Temperature class
without	45	-40 up to +45	T6
without	60	-40 up to +60	T5
without	100	-40 up to +60	T4
60 mm	100	-40 up to +80	T4
160 mm	120	-40 up to +80	T4
160 mm	180	-40 up to +80	T3
260 mm	260	-40 up to +80	T2

TM-SH sensors are restricted to  $T_{Amb} = 60\text{ °C}$  and  $T_{Process} = 100\text{ °C}$

15.3.3.1.2 Mounted separately with a junction box

Neck extension element	Process temperature (°C)	Ambient temperature range (°C)	Temperature class
without	45	-40 up to +45	T6
without	60	-40 up to +60	T5
without	100	-40 up to +80	T4
100 mm	120	-40 up to +80	T4
100 mm	180	-40 up to +80	T3
200 mm	260	-40 up to +80	T2

15.3.3.1.3 Mounted to the transmitter

Neck extension element	Process temperature (°C)	Max. ambient temperature (°C)	Temperature class
without	45	+45	T6
without	60	+55	T5
without	100	+50	T4
100 mm	120	+50	T4
100 mm	150	+50	T3

The values for ambient temperature mentioned in the certificate of the transformer have to be regarded.

15.3.3.2 For type TMS-\*\*\*\*-\*\*\*\*\*-\*\*\*-A-\*\*-\*\*

Process temperature -50 °C up to (°C)	Ambient temperature range (°C)	Temperature class
125	-40 up to +60	T4
70	-40 up to +60	T5



16 **Report Number**

BVS PP 01.2105 EU, as of 07.11.2018

17 **Special Conditions for Use**

- 17.1 If the sensor is mounted separately from the transmitter, equipotential bonding between the transmitter and the sensor must be guaranteed.
- 17.2 For the application of the sensor in an ambient temperature of less than -20 °C and higher than +60 °C cables and cable entries suitable for this condition shall be used.
- 17.3 The measuring tubes built of corrosion-resistant steel may have a thickness of < 1 mm. During installation and operation it must be ensured that risks e.g. by the medium or by mechanical damages are excluded.

18 **Essential Health and Safety Requirements**

The Essential Health and Safety Requirements are covered by the standards listed under item 9.


19 **Drawings and Documents**

Drawings and documents are listed in the confidential report.

---

We confirm the correctness of the translation from the German original.  
In the case of arbitration only the German wording shall be valid and binding.

DEKRA EXAM GmbH  
Bochum, dated 2018-11-07  
BVS-Fro/Ben/Mu A 20170496

  
\_\_\_\_\_  
Certifier

  
\_\_\_\_\_  
Approver